



City of Danville, Virginia

PO Box 3300
Danville, VA 24543

427 Patton Street, Rm 304
Danville, VA 24541

J. Gary Via, CPPO
Director of Purchasing
e-mail: viajg@danvilleva.gov

Phone: (434) 799-6528
Fax: (434) 799-5102
e-mail: purchasing@danvilleva.gov

March 19, 2019
IFB 18-19-061
"Danville Water Treatment Plant Filter Valves Improvements"
Addendum No. 3

Addendum No. 3 includes modifications to the Contract Drawings, Contract Specifications, and Bid Documents as described below. In addition to the noted modifications, responses and clarifications for questions received from prospective bidding contractors are also provided:

1. The plans and specs state that pipe cannot be supported off of pipe. The new pipe supports we are installing are only on the new piping, correct? Meaning we should not need new pipe supports at the north filters because that is only changing out the valves and flow meters.
Response: To the greatest extent possible, pipes should not be supported by other pipes, particularly for new work. The Engineer will work with the Contractor on a case-by-case basis should there be a need to make exceptions to this requirement. Existing pipe supports not shown to be removed/replaced shall remain. New pipe supports shall be part of the installation of new piping systems.
2. Are the supports, bolt kits, and anchors to be 304 Stainless Steel or 316 Stainless Steel?
Response: Supports, bolt kits, and anchors shall be Type 304 Stainless Steel.
3. Are all pipe supports made of stainless steel?
Response: Pipe supports shall be Type 304 Stainless Steel.
4. The plan elude to painting CMU. Where are we painting CMU, just where the new wall section attaches to block?
Response: The reference to CMU in Note 3 under the General Finish Notes on Sheet M1.5 is a general reference and is not for a specific location; therefore, disregard if it does not apply. However, in the south filter pipe gallery area, the areas where the new enclosure system is connected/anchored to existing substrates shall be prepared and painted in accordance with the manufacturer's instructions and applicable standards. Owner and Engineer will approve of the proposed coatings, including color selection.

Any other specifications remain the same.



J. Gary Via, Director of Purchasing

Company Name: _____ Signature: _____

Address: _____ Signature: _____

(Printed)

_____ Title: _____

City State Zip Code

Date: _____ e-mail address: _____

Phone No: _____ Fax No: _____